

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20202021/82237

DATE: 03/02/2021

From :

The Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.

To :


THE SECRETARY ASANSOL NORTH POINT SCHOOL  
G+3 SCHOOL BUILDING OF ASANSOL NORTH POINT SCHOOL OVER PLOT  
NO.640,647,635,636,638,641,642,645,KH.N O.182/1,11,201,12,130,155,156,UNDER  
JAMURIA MUNICIPALITY  
Asansol F.S., Jamuria PS,  
Paschim Bardhaman - 713339 .

Sub :Fire Safety Certificate for the occupancy of an existing construction of G + 3  
storied building under group Educational at the premises no.- ASANSOL NORTH  
POINT SCHOOL . OVER PLOT NO.640,647,635,636,638,641,642,645,KH.N  
O.182/1,11,201,12,130,155,156,UNDER JAMURIA MUNICIPALITY, Jamuria PS, Paschim  
Bardhaman - 713339

This is in reference to your Application No. IND/WB/FES/20202021/82237, dated 03/02/2021,  
regarding the Fire Safety Certificate for the occupancy of an existing construction of G + 3  
storied building under group Educational at the premises no.- ASANSOL NORTH POINT  
SCHOOL . OVER PLOT NO.640,647,635,636,638,641,642,645,KH.N  
O.182/1,11,201,12,130,155,156,UNDER JAMURIA MUNICIPALITY, Jamuria PS, Paschim  
Bardhaman - 713339.

The performance of the Fire Fighting System as incorporated in the buildings were tested at  
random and found satisfactorily working condition. In view of the above this office is releasing  
the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety  
measures need to be incorporated / maintained.



Principal  
Asansol North Point School  
Affiliated to C. B. S. E. New Delhi  
Affi. No. 2430153, School Code : 15541  
NH-2, Chanda, Jamuria


P. Das  
27/6/23


Manager  
Asansol North Point School  
Affiliated to C. B. S. E., New Delhi (2430153)  
NH-2, Chanda, Jamuria-713339

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.
2. The interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for anuwhere and tear in them, particularly lines above false ceiling & ducts.
5. The fire check door shall be sealed with rubber sealing properly in order to prevent the per collation of smoke.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the Building.
7. Floor number and directional sign of escape route shall be displayed prominently.
8. Mock fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
9. First Aid Fire fighting system shall ve provided as per I.S Specification.
10. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building to keep them inperfectly good working condition at all the times.
11. Fire license shall have to be attained for storing and processing with L.P.G and other combustibile articles.
12. All the teaching and non- teaching staff shall have adequate knowledge of using Fire Extinguisher and action to be taken for evacuation of building in case of emergency.
13. The Fire Safety Certificate is valid for a period of 3 years from the date of issued, and has to be renewed after 3 years, certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements and installation of the building.

**Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**

Signature valid  
Digitally signed by NITAI  
CHATTOPADHYAY  
Date: 2021.02.03 14:46:17 IST

  
**Principal**  
Asansol North Point School  
Affiliated to C. B. S. E. New Delhi  
Affi. No. 2430153, School Code : 15541  
NH-2, Chanda, Jamuria

  
**Manager**  
**Asansol North Point School**  
Affiliated to C. B. S. E., New Delhi (2430153)  
NH-2, Chanda, Jamuria-713339